

CHAPTER 61

LIQUEFIED PETROLEUM GASES

6101.1. Scope. Storage, handling and transportation of LP-gas and the installation of LP-gas equipment pertinent to systems for such uses shall comply with this chapter and NFPA 58. Properties of LP-gases shall be determined in accordance with Appendix B of NFPA 58. *The transportation, storage handling and use of liquefied petroleum gas and the installation and maintenance of all pertinent equipment is subject to the approval of the fire official.*

6103.1 General. Liquefied petroleum gas equipment shall be installed in accordance with the *International Fuel Gas Code* and NFPA 58, except as otherwise provided in this chapter *or in other laws or regulations legally in effect.*

6104.1 Within the limits of the City of Corpus Christi no storage container shall be installed, erected or used for a capacity to hold more than one hundred fifty (150) water gallons, except as follows:

- 6104.1.1.1 Installations accessory to service stations as permitted by the zoning ordinance, when the aggregate capacity of any one (1) installation does not exceed two thousand (2,000) gallons of water capacity.*
- 6104.3.1.1.2 Installations accessory to industrial uses permitted in areas zoned industrial, when the aggregate capacity of any one such installation does not exceed two thousand (2,000) gallons of water capacity, except that in particular installations this capacity limit may be altered at the discretion of the Fire Official to increase the maximum allowable capacity to not more than eight thousand (8,000) gallons of water capacity after consideration of special features such as topographical conditions, nature of occupancy and proximity of buildings, capacity of proposed tanks, degree of private fire protection to be provided, and facilities of the local fire department.*
- 6104.1.1.3 Installations in heavy industry zoning district..*
- 6104.1.1.4 The restrictions in Section 6104.1 do not apply to containers used for transportation purposes.*
- 6104.1.1.5 Containers larger than one hundred fifty (150) water gallons capacity may be authorized and installed only after applicant has first obtained and presented to the Fire Official a written approval of such installation of the*

*Director, Liquefied Petroleum Gas Division, Railroad
Commission of Texas.*